

Confirmation

LEED

On 24 October 2017, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

Sikaflex-118 Extreme Grab

supplied by

Sika Services AG


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EMICODE, Indoor Air Comfort GOLD testing standards (See test report no. 392-2017-00374101_A_EN).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of EMICODE 2015 (EC1 PLUS), and the formaldehyde limit of 10 $\mu\text{g}/\text{m}^3$ after 28 days
- the requirements of Indoor Air Comfort GOLD version 6.0 (February 2017).

6 September 2018



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry



Paul Santner
Consultant

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.