

Attestation

M1

On 20 May 2014, Eurofins Product Testing A/S received a sample of a flooring system with the product name:

Sikafloor®-20 PurCem

supplied by

Sika Deutschland GmbH

The emissions were tested according to 'M1 Protocol for Chemical and Sensory Testing of Building Materials' as published by Rakennustietosäätiö (version of 1.1.2014). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 392-2014-00087003E.

Evaluation of the emission test result according to M1:

- The sum of VOC ("TVOC") after 28 days was below the limit of 0.2 mg/m²h .
- Formaldehyde after 28 days was below the limit of 0.05 mg/m²h.
- Ammonia after 28 days was below the limit of 0.03 mg/m²h.
- Carcinogenic substances after 28 days were below the limit of 0,005 mg/m²h.
- Odour intensity after 28 days not worse than the limit of 0.1.

The tested product complies with the requirements of M1 label for use in the indoor environment.

13 August 2014



Maria Pelle
Chemist



Søren Ryom Villadsen
Analytical Service Manager