

# Confirmation

## LEED v4 and v4.1

On 2 February 2021, Eurofins Product Testing A/S received a sample of resin based floor coating with the product name:

**Sikafloor®-29 PurCem®**

supplied by

**Sika Deutschland GmbH**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH 01350 and ASTM D2369 testing standards (See test report no. 392-2021-00059901\_H\_EN and no. 392-2021-00059915\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (February 2021) projects globally by showing compliance with the specifications for VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.


**VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): South Coast Air Quality Management District (SCAQMD) Rule 1113 (2016) for Floor Coatings having a VOC content below 50 g/L.

13 April 2021



Pernille Krintel  
Analytical Service Manager



Rasmus Stengard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*