

LEED ATTESTATION

Attestation

LEED Product Information acc. to LEED v4 for Building Design and Construction.

Sika certifies based on the present state of knowledge, that the product

Sikasil®-670 Fire

conforms to the LEED v4 EQ credit 2 **Low-emitting materials**. A representative sample of the manufactured product has been tested in an accredited laboratory according to the relevant testing standards.

VOC Emissions: According to LEED v4 VOC emissions are complying with the requirements of California Department of Public Health (CDPH) Standard Method v1.2. (January 2017) (both private office and class room). Additionally TVOC after 14 days measured as specified in CDPH SM is less than 0.5 mg/m³.

VOC Content: VOC content for the product is complying with the requirement of SCAQMD Rule 1168 (2005) for product type "Sealants" which is < 250 g/l.

Sika Technology AG

A handwritten signature in black ink, appearing to read "B. Bosshard".

Bernhard Bosshard

Core Technology Head Adhesive Systems

Sika Services AG

A handwritten signature in black ink, appearing to read "Völlm".

Christian Völlm

Corporate Product Engineer
TM Sealing & Bonding

Zürich, March 2018