

# Certificate

On 6 August 2008 Eurofins Product Testing A/S received a sample of a deck coating with the name

## Sikafloor-330 Sika Deutschland GmbH

The emissions were tested according to the AgBB-scheme and guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 765863F.

### Evaluation of the test result according to AgBB guidelines:

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
  - The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m<sup>3</sup>.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m<sup>3</sup>.
  - The sum of SVOC after 28 day was below the limit of 0.1 mg/m<sup>3</sup>.
  - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
  - The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
  - Formaldehyde after 28 days was below the limit of 120 µg/m<sup>3</sup>.
- 

**The tested product complies with the requirements of DIBt (June 2004) in combination with the NIK values from AgBB (March 2008) for use in the indoor environment.**

18 March 2009



---

Thomas Neuhaus  
Head of product emission test centre



---

Marianne Hansen  
M.Sc. (Chemistry)

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK-8464 Galten / Denmark

Tel +45 70 22 42 66  
Fax +45 70 22 42 55